



SPECIFICATION FOR ALTERATION TO ROAD WATER-PIPING UNDER ROADWAYS/ROAD RESERVES

This specification must be strictly adhered to and forms part of the accompanying permit conditions pursuant to Sections 221 and 222 of the Local Government Act 1999.

Accompanying Permit Number

Name

Address

Location of pipe/s

- (a) This Licence/Authorisation shall remain in force until revoked by the Council.
- (b) The piping shall be laid at least 600mm under the crown of the road, and for its entire length shall be at sufficient depth to avoid damage during roadworks and no less than 350mm along fence line or across reserves.
- (c) All due care shall be taken and the road shall be appropriately closed and signmarked during the laying of the pipe to ensure traffic safety, and the road shall be properly reinstated to the satisfaction of Council.
- (d) Permanent markers shall be erected at either side of the road to indicate the location of the crossing, and are to consist of steel droppers or posts extending at least 600mm above the ground level with non-corrosive metal tags of at least 180mm attached, showing the owner's name.
- (e) Piping crossing under a road carriageway shall be sheaved inside larger PVC or similar piping to give added protection from traffic compaction and roadworks and allow future pipe removal and replacement if necessary without the need to disturb the road surface again.
- (f) Council accepts no responsibility or liability for any damage or maintenance to structures erected or installed.
- (g) The owner/s of all structures authorised to be installed shall indemnify the Council against any liability arising as a result of their installation or presence.
- (h) Council may require the removal or relocation of authorised structures if considered necessary for safety reasons or future road works.

Specification acknowledged and agreed to.

Signature/s

Date